

CERTIFICATE OF CONSTANCY OF PERFORMANCE

LGAI Technological Center, S.A. (APPLUS)
Notified Body Nr. 0370

No.

0370-CPR-1250

In compliance with Regulation (EU) Nr. 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product:

SMOKE AND HEAT CONTROL SYSTEMS. VENTILATORS (FANS).

PRODUCT: **IFHT F400**

Placed on the market under the name of:

S&P SISTEMAS DE VENTILACIÓN, S.L.U.

C/ LLEVANT, 4
08150 PARETS DEL VALLÈS (BARCELONA)

And produced in the manufacturing plant:

22/32307508 (EUROPE), 22/32307509 (EUROPE), 22/32307510 (EUROPE) & 22/32307511

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard

EN 12101-3:2015

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on 20th January 2012 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body. It is confirmed on 24th February 2023.

The monitoring assessment will be done before 30th November 2023

Bellaterra, 24th February 2023




LGAI Technological Center, S.A.
Xavier Ruiz Peña
Managing Director, Product Conformity B.U.



This document is not valid without its technical annex; whose number coincides with that of the certificate.

You can check the validity of this certificate on our website: www.appluslaboratories.com/certified_products

The manufacturer, after the completion of the conformity assessment procedures and the declaration of performance, may affix the CE Marking under his responsibility



0370-CPR-1250

Annex according to **EN 12101-3:2015**

SMOKE AND HEAT CONTROL SYSTEMS. PART 3: SPECIFICATION FOR POWERED SMOKE AND HEAT CONTROL VENTILATORS (FANS)

CERTIFIED PERFORMANCE

| Essential characteristics | Clauses in this European Standard | Mandated level(s) or class(es) |
|---|-----------------------------------|---|
| Response delay - Opening under wind load within a given time; - Opening under snow load within a given time. | 4.1.1 | NA |
| | | NA |
| Operational reliability - Application categories; - Motor rating. | 4.2.2 | <ul style="list-style-type: none"> • Thermally uninsulated • For use inside/outside smoke reservoir • Direct feed/converter feed • Dual purpose use |
| | 4.2.3 | NPD |
| Effectiveness of smoke/hot gas extraction: - Gas flow and pressure maintenance during smoke and heat extraction test. | 4.3.2 | +/-20% (P _S) |
| Resistance to fire | 4.4 | F ₄₀₀ (120) |
| Ability to open under environmental conditions - Opening under wind load within a given time; - Opening under snow load within a given time. | 4.5 | NA |
| | | NA |
| Durability of operational reliability | 4.6 | NPD |

PASS; NPD = No Performance Determined; NA = Not Applicable

PRODUCT

1.- Application:

- Fan tested inside the furnace
- Fan F400 (120)
- Dual use
- Inlet air flow in vertical direction and outlet airflow in horizontal direction

2.- Characteristics:

- Motor: F400 V2 from WEG
 - Motor voltage: 400 V
 - Motor frequency: 50/60 Hz

3.- Accessories:

- DEF.ASP.IFHT
- INT-xx/6P-F400
- VSD CFW

The complete technical data of the certified range **IFHT F400** are detailed in the technical file and the range report n° 15/9872-2901 and 20/21609-8 M1.