LGAI Technological Center, S.A.
Campus UAB - Ronda de la Font del Carme s/n
08193 Bellaterra (Barcelona) - Spain
T +34 93 567 20 00
F +34 93 567 20 01
www.applus.com





CERTIFICATE



No

0370-CPR-1250

CERTIFICATE OF CONSTANCY OF PERFORMANCE

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product:

SMOKE AND HEAT CONTROL SYSTEMS. PART 3: SPECIFICATION FOR POWERED SMOKE AND HEAT CONTROL VENTILATORS (FANS)
PRODUCT RANGE IFHT F400₁₂₀

Produced by:

SOLER Y PALAU SISTEMAS DE VENTILACIÓN, S.L.U.

C/ LLEVANT, 4 08150 PARETS DEL VALLÈS (BARCELONA)

And produced in the manufacturing plant:

17/32301811 (EUROPE) & 17/32301814 (EUROPE) & 17/32301816 (EUROPE)

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard

EN 12101-3:2015

under system 1 are applied and that the product fulfils all the prescribed requirements set out above.

This certificate was first issued on 20th January 2012 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly. It is confirmed and modified on 24th November 2017.

The monitoring assessment will be done before November 2018

Bellaterra, 24th November 2017

Applus[®]

LGAI Technological Center, S.A Jordi Brufau Redondo General Manager Arplus

LGAT Technological Center, S.A.

Xavier Ruiz Peña Product Conformity B.U., Managing Director

This document is not valid without its technical annex, whose number coincides with the number of certificate.



LGAI

LGAI Technological Center, S.A. (APPLUS)
Campus UAB s/n – Ronda de la Font del Carme, s/n
E - 08193 Bellaterra (Barcelona)
T +34 93 567 20 00
F +34 93 567 20 01
www.appluslaboratories.com



Technical Annex Ed.5 19/05/2017

TECHNICAL ANNEX 0370

0370-CPR-1250

CERTIFICATE OF CONSTANCY OF PERFORMANCE

1.- Application:

- Extractor tested inside the furnace.
- Extractor F400 (120).
- Dual use.

2.- Characteristics:

- Motor: WEG
- Rated Voltage motor: 400 V.

3.- Accessories:

- Inlet guard protection made by steel wire.
- Internal and outlet deflectors made of 1.5 mm galvanized steel sheet.
- External terminal box "B8A65M32" and "IP65" by NPF.
- Protection guard and flow straightener.
- Frequency converter type "CFW090060 T3848 SSZ" by WEG.

The complete technical data of the certified range **IFHT F400**₁₂₀ are detailed in the technical file and the range report no 15/9872-2901.

Essential characteristics	Clauses in this European Standard	Mandated level(s) or class(es)
Response delay - Opening under wind load within a given time; - Opening under snow load within a given time.	4.1.1	NA
		NA
Operational reliability - Application categories; - Motor rating.	4.2.2	Thermally uninsulatedInstallation inside smoke reservoir.Direct/converter feedDual purpose use
	4.2.3	NPD
Effectiveness of smoke/hot gas extraction: - Gas flow and pressure maintenance during smoke and heat extraction test.	4.3.2	+/-20% (P _s)
Resistance to fire	4.4	F400(120)
Ability to open under environmental conditions - Opening under wind load within a given time; - Opening under snow load within a given time.	4.5	NA
		NA
Durability of operational reliability	4.6	NPD

PASS; NPD = No Performance Determined; NA = Not Applicable

